

the Access BPL system shall be capable of attenuating emissions within that band to a level at least 20 dB below the applicable part 15 limits.

(ii) For frequencies above 30 MHz, when a notch filter is used to avoid interference with a specific frequency band, the Access BPL system shall be capable of attenuating emissions within that band to a level at least 10 dB below the applicable part 15 limits.

(iii) At locations where an Access BPL operator attenuates radiated emissions from its operations in accordance with the above required capabilities, we will not require that operator to take further actions to resolve complaints of harmful interference to mobile operations.

(2) Access BPL systems shall comply with applicable radiated emission limits upon power-up following a fault condition, or during a start-up operation after a shut-off procedure, by the use of a non-volatile memory, or some other method, to immediately restore previous settings with programmed notches and excluded bands, to avoid time delay caused by the need for manual re-programming during which protected services may be vulnerable.

(3) Access BPL systems shall incorporate a remote-controllable shut-down feature to deactivate, from a central location, any unit found to cause harmful interference, if other interference mitigation techniques do not resolve the interference problem.

[70 FR 1374, Jan. 7, 2005, as amended at 71 FR 49379, Aug. 23, 2006]

§ 15.613 Measurement procedures.

Compliance measurements for Access BPL shall be made in accordance with the Guidelines for Access BPL systems specified by the Commission.

§ 15.615 General administrative requirements.

(a) *Access BPL Database.* Entities operating Access BPL systems shall supply to an industry-recognized entity, information on all existing Access BPL systems and all proposed Access BPL systems for inclusion into a publicly available data base, within 30 days prior to initiation of service. Such information shall include the following:

(1) The name of the Access BPL provider.

(2) The frequencies of the Access BPL operation.

(3) The postal zip codes served by the specific Access BPL operation.

(4) The manufacturer and type of Access BPL equipment and its associated FCC ID number, or, in the case of Access BPL equipment that has been subject to verification, the Trade Name and Model Number, as specified on the equipment label.

(5) The contact information, including both phone number and e-mail address of a person at, or associated with, the BPL operator's company, to facilitate the resolution of any interference complaint.

(6) The proposed/or actual date of Access BPL operation.

(b) The Access BPL database manager shall enter this information into the publicly accessible database within three (3) business days of receipt.

(c) No notification to the Commission is required.

(d) A licensed spectrum user experiencing harmful interference that is suspected to be caused by an Access BPL system shall inform the local BPL operator's contact person designated in the Access BPL database. The investigation of the reported interference and the resolution of confirmed harmful interference from the Access BPL system shall be successfully completed by the BPL operator within a reasonable time period according to a mutually acceptable schedule, after the receipt of an interference complaint, in order to avoid protracted disruptions to licensed services. The Access BPL operator shall respond to complaints of harmful interference from public safety users within 24 hours. With regard to public safety complaints, the BPL provider shall be required to immediately cease the operations causing such complaint if it fails to respond within 24 hours.

(e) *Consultation with public safety users.* An entity operating an Access BPL system shall notify and consult with the public safety users in the area where it plans to deploy Access BPL, at least 30 days prior to initiation of any operation or service. This entity shall design or implement the Access